

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1220326

Product: Voltage limiting device (VLD) class 2.2

Type: BVL-25-120-R01, BVL-50-45-R02, BVL-50-60-R02, BVL-50-120-R02,
BVL-100-45-R02, BVL-100-60-R02, BVL-100-120-R02

Rating: BVL-25-120-R01: $I_r = 25 \text{ A}$, $U_{Tn} = 120 \text{ V}$, $I_w = 1 \text{ kA @ } 0,1 \text{ s}$,
BVL-50-...-R02: $I_r = 50 \text{ A}$, $U_{Tn} = 45/60/120 \text{ V}$, $I_w = 16 \text{ kA @ } 0,03 \text{ s}$,
BVL-100-...-R02: $I_r = 100 \text{ A}$, $U_{Tn} = 45/60/120 \text{ V}$, $I_w = 16 \text{ kA @ } 0,03 \text{ s}$

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 221283-01/01 of: 27.06.2022

A sample of the product was found to be in conformity with:
ČSN EN 50526-2:2014 (idt EN 50526-2:2014)

Other data:

The validity of the certificate is limited to: 10.07.2025

11.07.2022

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



221283-01