

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1220413

Product: Surge protective device (SPD) type 1 and type 2

Type: FLP-12,5-075-VH/1(S), FLP-12,5-075-VH/2(S)

Rating: $U_c = 75$ V AC/DC, $I_n = 20$ kA, $I_{imp} = 12,5$ kA, $I_{max} = 40$ kA

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 221699-01/01 of: 19.08.2022

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:13+A11:18
(idt EN 61643-11:12+A11:18, mod IEC 61643-11 ed. 1.0:11)

Other data:

The validity of the certificate is limited to: 23.08.2025

24.08.2022

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



221699-01