

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1220448

**Product:** Surge protective device (SPD) for data, signalling and telecommunications networks

**Type:** DM-006/1-R-DJ, DM-012/1-R-DJ, DM-024/1-R-DJ, DM-024/1R-VAK-DJ,  
DMG-024/1-R-DJ, DM-048/1-R-DJ, DM-012/1-L2-DJ, DM-024/1-L2-DJ,  
DM-048/1-L2-DJ

**Rating:**  $U_c = 6/11/25/36 (35,6) \text{ V AC}$ ;  $U_c = 8,5/16/36/51 (50,2) \text{ V DC}$ ;  $I_L = 0,5/2 \text{ A}$

**Ordering firm:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Manufacturer:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 221928-01/01 of: 12.09.2022

A sample of the product was found to be in conformity with:  
ČSN EN 61643-21:02+A1:10+A2:13, (idt EN 61643-21:01+A1:09, A2:13)

**Other data:**

The validity of the certificate is limited to: 19.09.2025

20.09.2022

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



\* C E R / 1 2 2 0 4 4 8 \*

221928-01