

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lísem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1220566

**Product:** Surge protective device (SPD) type 3

**Type:** DA-275 V/1+1, DA-275 V/1S+1, DA-275 V/3+1, DA-275 V/3S+1

**Rating:** L-N:  $U_c = 275 \text{ V AC}$ ,  $U_{oc} = 10 \text{ kV}$ ,  $U_p = 1,0 \text{ kV}$   
N-PE:  $U_c = 255 \text{ V AC}$ ,  $U_{oc} = 20 \text{ kV}$ ,  $U_p = 1,5 \text{ kV}$

**Ordering firm:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Manufacturer:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 222644-01/01 of: 30.11.2022

**A sample of the product was found to be in conformity with:**  
ČSN EN 61643-11 ed. 2:13+A11:18 (idt EN 61643-11:12+A11:18, mod IEC 61643-11 ed. 1.0:11)

**Other data:**

**The validity of the certificate is limited to:** 05.12.2025

06.12.2022

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



222644-01