

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1220573

Product: Surge protective device (SPD) type 1 and type 2 for photovoltaic systems

Type: FLP-PV1000/Y, FLP-PV1000/YS, FLP-PV1500/Y, FLP-PV1500/YS

Rating: FLP-PV1000/Y(S): $U_{CPV} = 1050$ V DC, $I_{SCPV} = 20$ kA, $I_{Total} = 12,5$ kA (10/350),
FLP-PV1500/Y(S): $U_{CPV} = 1500$ V DC, $I_{SCPV} = 20$ kA, $I_{Total} = 12,5$ kA (10/350)

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Factories: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 222564-01/01 of: 07.12.2022

A sample of the product was found to be in conformity with:
ČSN EN 61643-31:2019 (idt EN 61643-31:2019), IEC 61643-31 ed. 1.0:2018

Other data:

The validity of the certificate is limited to: 12.12.2025

13.12.2022

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



222564-01