

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lísem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1230027

Product: Surge protective device (SPD) type 3 with passive filter

Type: DPF-012DC-16(-S), DPF-024DC-16(-S), DPF-048DC-16(-S)

Rating: DPF-012DC-16(-S): $U_c=20$ V AC/DC, $U_{oc}=4$ kV, $U_p=250/500$ V,
DPF-024DC-16(-S): $U_c=34$ V AC/DC, $U_{oc}=4$ kV, $U_p=290/500$ V,
DPF-048DC-16(-S): $U_c=60$ V AC/DC, $U_{oc}=4$ kV, $U_p=420/500$ V

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 230138-01/01 of: 31.01.2023

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:13+A11:18 (idt EN 61643-11:12+A11:18, mod IEC 61643-11 ed. 1.0:11)

Other data:

The validity of the certificate is limited to: 01.02.2026

02.02.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



230138-01