



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1230028

**Product:** Surge protective device (SPD) type 3

**Type:** DP-012-25, DP-024-25, DP-048-25

**Rating:** DP-012-25:  $U_c=20$  V AC/DC,  $U_{oc}=4$  kV,  $U_p=180/550$  V,  
DP-024-25:  $U_c=34$  V AC/DC,  $U_{oc}=4$  kV,  $U_p=230/550$  V,  
DP-048-25:  $U_c=60$  V AC/DC,  $U_{oc}=4$  kV,  $U_p=380/550$  V

**Ordering firm:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Manufacturer:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 230137-01/01 of: 31.01.2023

**A sample of the product was found to be in conformity with:**  
ČSN EN 61643-11 ed. 2:13+A11:18 (idt EN 61643-11:12+A11:18, mod IEC 61643-11 ed. 1.0:11)

**Other data:**

**The validity of the certificate is limited to:** 01.02.2026

02.02.2023

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



\* C E R / 1 2 3 0 0 2 8 \*

230137-01