

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1230275

Product: Surge protective device (SPD) type 2 for IT power systems

Type: SLP-600-V/3YS-IT

Rating: $U_c = 760$ V AC
 $I_n = 20$ kA
 $I_{max} = 40$ kA

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 231432-01/01 of: 20.06.2023

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:13+A11:18 (idt EN 61643-11:12+A11:18, mod IEC 61643-11 ed. 1.0:11)

Other data:

The validity of the certificate is limited to: 26.06.2026

27.06.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



231432-01