

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod liseň 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1230349

Product: Surge protective device (SPD) type 1 and type 2

Type: FLP-12,5 V/1 (S), FLP-12,5 V/1(S)+1, FLP-12,5 V/2 (S), FLP-12,5 V/3 (S),
FLP-12,5 V/3(S)+1, FLP-12,5 V/4 (S)

Rating: L-N: $U_C = 275$ V AC, $I_n = 30$ kA, $I_{imp} = 12,5$ kA, $I_{max} = 60$ kA,
N-PE 25: $U_C = 255$ V AC, $I_n = 30$ kA, $I_{imp} = 25$ kA, $I_{max} = 60$ kA,
N-PE 50: $U_C = 255$ V AC, $I_n = 50$ kA, $I_{imp} = 50$ kA, $I_{max} = 100$ kA

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 231809-01/01 of: 31.07.2023

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:13+A11:18 (idt EN 61643-11:12+A11:18, mod IEC 61643-11 ed. 1.0:11)

Other data:

The validity of the certificate is limited to: 06.08.2026

07.08.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



231809-01