

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 182 00 Praha 8, Troja

## CERTIFICATE

No.: 1230470

**Product:** Surge protective device (SPD) type 1 and type 2 for photovoltaic systems

**Type:** FLP-PV275 V/U

**Rating:**  $U_{CPV} = 280$  V DC,  $I_{SCPV} = 10$  kA,  $I_{Total} = 25$  kA (10/350)

**Ordering firm:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Manufacturer:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 232039-01/01 of: 27.9.2023

**A sample of the product was found to be in conformity with:**  
ČSN EN 61643-31:2019 (idt EN 61643-31:2019),  
IEC 61643-31 ed. 1.0:2018

**Other data:**

**The validity of the certificate is limited to:** 22.10.2026

23.10.2023

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



232039-01