

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 182 00 Praha 8, Troja

CERTIFICATE

No.: 1230471

Product: Surge protective device (SPD) type 2

Type: SLP-075-VB/1(S), SLP-150-VB/1(S), SLP-275-VB/1(S), SLP-275-VB/3(S),
SLP-275-VB/4(S), SLP-275-VB/1(S)+1, SLP-275-VB/3(S)+1

Rating: SLP-075-VB: $U_c = 75$ V AC, $I_n = 20$ kA, $I_{max} = 40$ kA, $U_p = 0,8$ kV
SLP-150-VB: $U_c = 150$ V AC, $I_n = 20$ kA, $I_{max} = 40$ kA, $U_p = 1,2$ kV
SLP-275-VB: $U_c = 275$ V AC, $I_n = 20$ kA, $I_{max} = 40$ kA, $U_p = 1,5$ kV

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 232008-01/01 of: 27.09.2023

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:13+A11:18 (idt EN 61643-11:12+A11:18, mod IEC 61643-11 ed. 1.0:11)

Other data:

The validity of the certificate is limited to: 31.10.2026

23.10.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



232008-01