

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod líslem 129/2, 182 00 Praha 8, Troja

## CERTIFICATE

No.: 1230475

**Product:** Lightning Current Arrester (SPD) type 1 and type 1,2

**Type:** FLP-B+C-MAXI-VSF/1, FLP-B+C-MAXI-VSF/3,  
FLP-B+C-MAXI-VSF/3+1, FLP-B+C-MAXI-VSF /4,  
FLP-25-T1-VSF/1, FLP-25-T1-VSF/3, FLP-25-T1-VSF/3+1,  
FLP-25-T1-VSF/4

**Rating:** FLP-B+C-MAXI-VSF: UC = 260 V AC, I<sub>imp</sub> = 25 kA, I<sub>n</sub> = 30 kA, I<sub>max</sub> = 60 kA, U<sub>p</sub> = 1,5 kV  
FLP-25-T1-VSF: UC = 260 V AC, I<sub>imp</sub> = 25 kA, U<sub>p</sub> = 1,5 kV

**Ordering firm:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Manufacturer:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 231790-01/01 of: 27.9.2023

**A sample of the product was found to be in conformity with:**  
ČSN EN 61643-11 ed. 2:2013+A11:2018  
(idt EN 61643-11:2012+A11:2018, mod IEC 61643-11 ed. 1.0:2011)

**Other data:**

**The validity of the certificate is limited to:** 22.10.2026

23.10.2023

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



231790-01