

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 182 00 Praha 8, Troja

## CERTIFICATE

No.: 1230484

**Product:** Voltage limiting device (VLD) class 1

**Type:** SCG-250-075-R01, SCG-250-250-R01,  
SCG-250-500-R01, SCG-250-750-R01

**Rating:**  $I_r = 250 \text{ A @ 60 min}$ ,  $I_w = 1 \text{ kA @ 60 ms}$   
SCG-250-075-R01:  $U_{Tn} = 75 \text{ V}$   
SCG-250-250-R01:  $U_{Tn} = 250 \text{ V}$   
SCG-250-500-R01:  $U_{Tn} = 480 \text{ V}$   
SCG-250-750-R01:  $U_{Tn} = 750 \text{ V}$

**Ordering firm:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Manufacturer:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 232395-01/01 of: 26.10.2023

A sample of the product was found to be in conformity with:  
ČSN EN 50526-2:14 (idt EN 50526-2:14)

**Other data:**

The validity of the certificate is limited to: 29.10.2026

30.10.2023

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



232395-01