

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1250060

Product: Surge protective device (SPD) type 1 and type 2

Type: FLP-EV12,5-VBH/1(S)+1, FLP-12,5-VBH/3(S), FLP-EV12,5-VBH/3(S)+1,
FLP-12,5-VBH/4(S)

Rating: L-N: $U_C = 275 \text{ V AC}$, $I_n = 30 \text{ kA}$, $I_{imp} = 12,5 \text{ kA}$, $I_{max} = 60 \text{ kA}$,
N-PE 25: $U_C = 255 \text{ V AC}$, $I_n = 30 \text{ kA}$, $I_{imp} = 25 \text{ kA}$, $I_{max} = 60 \text{ kA}$,
N-PE 50: $U_C = 255 \text{ V AC}$, $I_n = 50 \text{ kA}$, $I_{imp} = 50 \text{ kA}$, $I_{max} = 100 \text{ kA}$

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 250168-01/01 of: 30.01.2025

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:2013+A11:2018 (idt EN 61643-11:2012+A11:2018, mod IEC 61643-11 ed. 1.0:2011)

Other data:

The validity of the certificate is limited to: 02.02.2028

03.02.2025

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



250168-01